

ADDENDUM NO. 2

CRAIG HIGH SCHOOL BIOMASS PROJECT

TO: ALL PLANHOLDERS

Date: March 13, 2023

.....
The following information is provided to the potential Bidders for the above named Project and shall become a part of the bidding and contract documents, dated 12.9.22. No consideration will be allowed due to any potential Bidder not being aware of or familiar with this addendum.

The Bidder must acknowledge receipt of this addendum on its Bid Proposal Form in order for its Bid to be deemed acceptable. This addendum shall form part of the Invitation to Bid (IFB) and is to be read, interpreted, and coordinated with all other parts. The Addendum No. 1 contains 1 page in total and (4) PDF attachments titled "C1.0" containing 1 page, "235250 – WOOD BOILER SYSTEM-Add 2" containing 5 pages, "CRHS_BOIMASS_ADD02_M1.0_230310" containing 1 page, and "CRHS_BOIMASS_ADD02_M2.1_230310" containing 1 page.

.....
Description of addendum:

CIVIL:

1. **REVISION: C1.0: Liquid Propane Scope of Work:**
Contractor WILL NOT be responsible for the scope of work to supply the Propane Tank, The tank's components, nor the piping between the building and the tank. See C1.0 for clarification.

MECHANICAL:

2. **REPLACEMENT: SPECIFICATIONS: SECTION 235250 – WOOD BOILER SYSTEM**
Replace specification in it's entirety with attached specification. See attached pdf "235250 – WOOD BOILER SYSTEM-Add 2"
3. **MODIFICATION: SHEET M1.0 – MECHANICAL SCHEDULES & LEGEND**
Wood Boiler System Note D as shown on the revised drawing. See attached pdf "CRHS_BOIMASS_ADD02_M1.0_230310"
4. **ADDITION: SHEET M2.1 – BOILER PLANT MECHANICAL PLAN**
Add 30 gallon plastic drum for boiler system overflow as shown on the revised drawing. See attached pdf "CRHS_BOIMASS_ADD02_M2.1_230310".